

**TITLE 4. PROFESSIONS AND OCCUPATIONS****CHAPTER 36. DEPARTMENT OF BUILDING AND FIRE SAFETY**(Authority: A.R.S. § 41-2141 *et seq.*)**ARTICLE 1. RESERVED****ARTICLE 2. STATE FIRE SAFETY COMMITTEE**

4 A.A.C. 34, Article 11, consisting of Section R4-34-1101, renumbered to A.A.C. R4-36-201 (Supp. 95-4). Introduction and Section number below corrected (Supp. 97-4).

Article 11 consisting of Section R4-34-1101 adopted as a permanent rule effective November 16, 1988.

Article 11 consisting of Section R4-34-1101 adopted as an emergency effective March 14, 1988 pursuant to A.R.S. § 41-1026, valid for only 90 days. Emergency expired.

Section

R4-36-201. Arizona State Fire Code

**ARTICLE 3. REPEALED**

Article 3, consisting of Sections R4-26-301 through R4-36-308, repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Interim effective date corrected Supp. 98-2. Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

Article 3, consisting of Sections R4-36-301 through R4-36-308, adopted effective November 1, 1995 (Supp. 95-4). Introduction corrected (Supp. 97-4).

**ARTICLE 1. RESERVED****ARTICLE 2. STATE FIRE SAFETY COMMITTEE****R4-36-201. Arizona State Fire Code**

- A.** All persons residing, doing business or who are physically present within the state of Arizona shall comply with the provisions and regulations of the Uniform Fire Code (1988 Ed.) determined by the International Conference of Building Officials and the Western Fire Chiefs Association, which is declared to be a part of this regulation as if set forth in full herein, subject to the deletions, modifications and amendments contained in subsection (B). Copies of the Uniform Fire Code (1988 Ed.) and copies of the Uniform Fire Code Standards (1988 Ed.), the Uniform Building Code (1988 Ed.), the Uniform Mechanical Code (1988 Ed.), and the Uniform Plumbing Code (1988 Ed.), referenced in the Uniform Fire Code (1988 Ed.), are incorporated herein by reference and on file with the Office of the Secretary of State. Incorporated materials do not include any later amendments or editions of the incorporated matter. Copies of these uniform codes are available from the International Conference of Building Officials, 5360 South Workman Mill Road, Whittier, California 90601.
- B.** The Uniform Fire Code (1988 Ed.) is modified as follows:
1. Pages xxvi, xxvii, xxviii and xxix are deleted.
  2. Where the term "Corporation Counsel" is used in the Uniform Fire Code, it shall mean the legal counsel of the jurisdiction or its fire department, or of the State Fire Marshal, as the context requires.
  3. Wherever the terms "Chief," "Chief of the Fire Department" or "Building Official" are used in the Uniform Building Code, in addition to the definitions set out in Article 9 of the Uniform Fire Code, these terms shall include the State Fire Marshal or designated representative, unless the context otherwise requires.

4. Wherever the terms "fire department," "department," "fire prevention engineer," or "bureau of fire prevention" are used in the Uniform Fire Code, in addition to the definitions set out in Article 9 of the Uniform Fire Code, these terms shall include the Office of State Fire Marshal, unless the context otherwise requires.
5. Sec. 1.102(b) is modified to include "The National Fire Code Standard and its appendices, published by the National Fire Protection Association (NFPA) as listed below, are incorporated herein by reference and on file with the Office of the Secretary of State. Incorporated materials do not include any later amendments or editions of the incorporated matter. Copies are available from the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269."
  - "i. NFPA #10 Portable Fire Extinguishers (1988 Ed.),
  - "ii. NFPA #12A Halon 1301 Fire Extinguishing Systems (1987 Ed.),
  - "iii. NFPA #12B Halon 1211 Fire Extinguishing Systems (1985 Ed.),
  - "iv. NFPA #13 Installation of Sprinkler Systems (1989 Ed.),
  - "v. NFPA #13A Inspection, Testing and Maintenance of Sprinkler Systems (1987 Ed.),
  - "vi. NFPA #13R Installation of Sprinkler Systems in Residential Occupancies up to Four Stories in Height (1989 Ed.),
  - "vii. NFPA #14 Standpipe & Hose Systems (1986 Ed.),
  - "viii. NFPA #15 Water Spray Fixed Systems (1985 Ed.),
  - "ix. NFPA #16 Foam Water Spray Systems (1986 Ed.),
  - "x. NFPA #17 Dry Chemical Extinguishing Systems (1985 Ed.),
  - "xi. NFPA #17A Wet Chemical Extinguishing Systems (1986 Ed.),
  - "xii. NFPA #20 Centrifugal Fire Pumps (1987 Ed.),
  - "xiii. NFPA #22 Water Tanks for Private Fire Protection (1987 Ed.),
  - "xiv. NFPA #24 Private Fire Service Mains (1987 Ed.),
  - "xv. NFPA #26 Valves Controlling Water Supplies for Fire Protection (1988 Ed.),
  - "xvi. NFPA #51B Cutting & Welding Processes (1984 Ed.),
  - "xvii. NFPA #58 Liquefied Petroleum Gases (1989 Ed.),
  - "xviii. NFPA #70 National Electrical Code (1987 Ed.),
  - "xix. NFPA #71 Installation, Maintenance and Use of Central Station Signaling Systems (1987 Ed.),
  - "xx. NFPA #72A Local Protective Signaling Systems (1987 Ed.),
  - "xxi. NFPA #72B Auxiliary Protective Signaling Systems (1986 Ed.),
  - "xxii. NFPA #72C Remote Station Protective Signaling Systems (1986 Ed.),
  - "xxiii. NFPA #72D Proprietary Protective Signaling Systems (1986 Ed.),

- “xxiv. NFPA #72E Automatic Fire Detectors (1987 Ed.),
- “xxv. NFPA #72H Testing Procedures for Local, Auxiliary, Remote Station and Proprietary Protective Signaling Systems (1988 Ed.),
- “xxvi. NFPA #80 Fire Doors and Windows (1986 Ed.),
- “xxvii. NFPA #86 Ovens and Furnaces, Design, Location, and Equipment (1985 Ed.),
- “xxviii. NFPA #90A Air Conditioning and Ventilating Systems (1985 Ed.),
- “xxix. NFPA #91 Blower and Exhaust Systems (1983 Ed.),
- “xxx. NFPA #96 Removal of Smoke and Grease-laden Vapors from Commercial Cooking Equipment (1987 Ed.),
- “xxxi. NFPA #231 Indoor General Storage (1987 Ed.),
- “xxxii. NFPA #231C Rack Storage of Materials (1986 Ed.),
- “xxxiii. NFPA #303 Fire Protection Standard for Marinas and Boatyards (1986 Ed.),
- “xxxiv. NFPA #407 Aircraft Fuel Servicing (1985 Ed.),
- “xxxv. NFPA #409 Aircraft Hangars (1985 Ed.),
- “xxxvi. NFPA #490 Ammonium Nitrate, Storage of (1986 Ed.),
- “xxxvii. NFPA #498 Explosives Motor Vehicle Terminals (1986 Ed.),
- “xxxviii. NFPA #651 Aluminum and Magnesium Powder (1987 Ed.),
- “xxxix. NFPA #704 Identification of the Fire Hazards of Materials (1985 Ed.),
- “xxxx. NFPA #1231 Water Supplies for Rural & Suburban Fire Fighting (1984 Ed.).”
6. Sec. 1.102(c) is modified to read “Wherever in the code reference is made to the appendix, only the following appendices shall be part of this code:
- “Appendix I-A with the exception of Section 1(b),
- “Appendix II-A,
- “Appendix II-B,
- “Appendix II-C with the exception of Section 2,
- “Appendix II-E,
- “Appendix IV-A,
- “Appendix V-A,
- “Appendix VI-A,
- “Appendix VI-D,
- “Appendix VI-E”.
7. Sec. 2.304(a) is modified by adding the following: “To the extent that the Uniform Fire Code Standards (1988 Ed.) incorporate NFPA Standards which are consistent with NFPA Standards incorporated by reference in Sec. 1.102(b), the version incorporated in Sec. 1.102(b) shall control.”
8. Sec. 4.101 is modified to read: “The authority having jurisdiction may require permits as provided for in Sec. 4.108 of this code.”
9. Sec. 11.204 is modified to include “educational occupancies.”
10. Add Sec. 11.210 to read: “Bed mattresses used in institutional occupancies where the personal liberties of inmates are restrained shall be permanently flame resistant and low-smoke producing. Urethane foam materials shall be aged before the following tests are conducted. The method of aging shall be by American Society for Testing and Materials (ASTM) D3574-86 Test J<sub>1</sub>” (1986 Ed.) which is incorporated by reference herein and on file with the Office of the Secretary of State. Incorporated materials do not include any later amendments or editions of the incorporated matter. This document is available from the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103. All materials shall meet the following criteria:

<u>TEST</u>	<u>ACCEPTABLE VALUES</u>	<u>TEST METHOD</u>
Oxygen Index %O <sub>2</sub>	50 min.	ASTM D-2863-87
Smoke Density Flaming Ds @ 90 Sec. & nonflaming DS @ 4 minutes	1 in-75 max.  1 in-175 max.	ASTM E-662-83
Radiant Panel	Flame Spread 5 or less- No melt, no drip	ASTM E-162-87”

11. Sec. 12.110 is added to Article 12 to read: “Fire exit drills shall be conducted in accordance with Chapter 31 of the NFPA #101, Life Safety Code” (1988 Ed.), which is incorporated by reference herein and on file with the Office of the Secretary of State. Incorporated materials do not include any later amendments or editions of the incorporated matter. This document is available from the National Fire Protection Association, Batterymarch Park, Quincy, MA 02269.”
12. Sec. 14.102. Modify the definition of alarm system to read: “Alarm system is a combination of a control unit and approved compatible devices with the necessary electrical interconnection and energy to produce an alarm signal in the event of fire or system activation.”
13. Sec. 14.103(b) is modified to read: “Fire alarm systems installed in educational, institutional, state or county-owned occupancies shall be designed and installed in such a manner that the failure, removal, or destruction of any single alarm actuating or alarm indicating device or a break in the wiring circuit will not interfere with the normal operation of any other such devices.”
14. Section 14.103(c) is modified to read: “Equipment. Systems and components shall be listed and approved for the purpose for which installed.”
15. Sec. 14.103(d) is modified to read: “Acceptance Test. Upon completion of the installation or alteration, a satisfactory test of the entire fire alarm system shall be made

- in the presence of the Chief. All functions of the fire alarm system or alteration shall be tested.”
16. Sec. 14.103(e) is modified to read: “The permittee shall provide written certification to the Chief that the system has been installed in accordance with the approved plans, component specifications and the manufacturer’s minimum requirements.”
  17. Sec. 14.104(b)(1) is modified to include paragraph D: “Group B, Division 2 occupancies owned by the state or county at the discretion of the Fire Marshal.”
  18. Sec. 14.104(b)(3) is modified to include paragraph D: “An automatic system shall be required when construction includes internal corridors which serve as egress pathways. Approved smoke detectors shall be installed in internal corridors in accordance with R4-34-1101(B)(5)(xxiv).”
  19. Sec. 14.104(c), first paragraph, is modified to read: “Group R, Division 1 Occupancies. A manual and automatic fire alarm system shall be installed in apartment houses three or more stories in height or containing more than 16 dwelling units and in hotels three or more stories in height or containing 20 or more guest rooms.” Remaining paragraphs are unchanged.
  20. Sec. 14.104(c), fourth paragraph, is modified to read: “An approved and listed system-type heat detector shall be installed within common areas such as recreational rooms, laundry rooms and furnace rooms of buildings containing Group R, Division 1 Occupancies.”
  21. Sec. 14.104(e) is modified to read: “Smoke detectors in dwelling units and guest rooms. Smoke detectors shall be installed as required by the Building Code Section 1210(a) in dwelling units and hotel or lodging house guest rooms. When such detectors are connected to a fire alarm system, they shall not sound a general alarm.”
  22. Sec. 14.105(d) is added to read: “Return wires of above-ground fire alarm system wiring shall be physically separated from outgoing wires by a distance of not less than six feet or by a minimum of one-hour fire-resistive construction. The six-foot separation shall not apply to underground installation. EXCEPTION: When making connections to the panel.”
  23. Sec. 14.106(a) is modified to read: “Maintenance and Testing. All fire alarm systems shall be maintained and tested as set forth in this Article and in accordance with nationally recognized standards. All fire alarm and detection systems shall be tested as set forth in R4-34-1101(B)(5)(xxv).”
  24. Sec. 14.108 is modified to read: “Accidental Alarms. In the event of temporary failure of the alarm system or an excessive number of accidental alarm activations, the Chief may require the building owner or occupant to provide standby personnel as defined by Sec. 25.117 until the system is restored.”
  25. “Sec. 14.109 is added to read: “Fire alarm systems installed in buildings used for public accommodation as defined in A.R.S. § 34-402(20) shall meet the requirements of A.R.S. § 34-431.”
  26. Add a new Division V of Article 25 to Read: “Division V. Grounds of Carnivals and Fairs.”
  27. Sec. 25.501 is added to read: “Scope. The grounds of carnivals and fairs, including concession booths, shall conform to the requirements of this division and all other applicable requirements of this code.”
  28. Sec. 25.502 is added to read: “Permits. For a permit to operate a carnival or fair, see Sec. 4.108.”
  29. Sec. 25.503 is added to read: “General Requirements. Grounds shall comply with the following:
    - “1. Fire apparatus access roads shall be provided in accordance with Sec. 32.105.
    - “2. Fire-fighting appliances shall be provided for the entire midway, as required by the chief.
    - “3. Maximum travel distance to a portable fire extinguisher shall not exceed 75 feet.
    - “4. All electrical equipment and installations shall comply with the National Electrical Code.”
  30. Sec. 25.504 is added to read: “Concession stand requirements. Concession stands shall comply with the following:
    - “1. Concession stands utilized for cooking shall have a minimum of 10 feet of clearance on two sides and shall not be located within 10 feet of amusement rides or devices.
    - “2. A 40-B:C-rated dry chemical fire extinguisher shall be provided where deep-fat fryers are in use.”
  31. Sec. 25.505 is added to read: “Internal combustion power sources, including motor vehicles, generators and similar equipment shall comply with the following:
    - “1. Fuel tanks shall be of adequate capacity to permit uninterrupted operation during normal operating hours. Refueling shall be conducted only when the ride is not in use.
    - “2. Internal combustion power sources shall be isolated from contact with the public by either physical guards, fencing or enclosures.
    - “3. At least one fire extinguisher with a rating of not less than 2-A:10B:C shall be provided.”
  32. Add a new Division VI of Article 25 to read: “Division VI. Liquid- or Gas-Fueled Vehicles or Equipment Used for Display or Competition Within Assembly Buildings.”
  33. Sec. 25.602 is added to read: “Scope. Liquid- or gas-fueled vehicles or equipment used for display competition or demonstration within an assembly building shall comply with the requirements of this division and all other applicable requirements of this code.”
  34. Sec. 25.602 is added to read: “Permits. For permits to use liquid- or gas-fueled vehicles or equipment for competition or display inside an assembly building, see Sec. 4.108.”
  35. Sec. 25.603 is added to read: “Display. Display of liquid- or gas-fueled vehicles or equipment inside an assembly building shall comply with the following:
    - “1. Batteries shall be disconnected in an approved manner.
    - “2. Vehicles or equipment shall not be fueled or defueled within the building.
    - “3. Fuel in the fuel tank shall not exceed one-quarter of the tank capacity or five gallons, whichever is less.
    - “4. Fuel systems shall be inspected for leaks.
    - “5. Fuel-tank openings shall be locked and sealed to prevent the escape of vapors.
    - “6. The location of such vehicles or equipment shall not obstruct or block exits.”
  36. Sec. 25.604 is added to read: “Competition or Demonstrations. Liquid- or gas-fueled vehicles or equipment used for competition or demonstration within an assembly building shall comply with the following:
    - “1. Fuel for the vehicles or equipment shall be stored in approved containers in an approved location outside of the building.
    - “2. Refueling shall be performed outside of the building at an approved site.

- “3. All fuel spills shall be cleaned up immediately.”
37. Sec. 80.101. Add a paragraph to read: “For retail display of nonflammable solid and nonflammable or noncombustible liquid hazardous materials in Group B, Division 2 retail sales occupancies, see Sec. 80.109.”
38. Sec. 80.109 is added to read: “Retail display. When in accordance with this section, the aggregate quantity of nonflammable solid and nonflammable or noncombustible liquid hazardous materials permitted within a single control area of a Group B, Division 2 retail sales occupancy may exceed the exempt amounts specified in Division III, Tables Nos. 80.306-A, 80.309-A, 80.310-A, 80.312-A, 80.314-A and 80.315-A. The maximum allowable quantity in pounds or gallons permitted within a single control area of a retail sales occupancy shall be the amount derived from the formula:
- $$E_R = E \times p \times A$$
- “WHERE:
- “ $E_R$  = exempt amount permitted in a single control area of a retail sales occupancy.
- “ $E$  = exempt amount specified in Division III exempt amount tables.
- “ $p$  = density factor from Table No. 80.109.
- “ $A$  = square footage area of the hazardous material retail display or storage.
- The maximum aggregate floor area for hazardous material retail display or storage over which the density factor may be applied shall not exceed 1500 square feet per control area.”

“The area of storage or display shall also comply with the following requirements:

- “1. Display of solids shall not exceed 200 pounds per square foot of floor area actually occupied by the solid merchandise.
  - “2. Display of liquids shall not exceed 20 gallons per square foot of floor area actually occupied by the liquid merchandise.
  - “3. Display height shall not exceed six feet.
  - “4. Individual containers less than five gallons or less than 25 pounds shall be stored on pallets, racks or shelves.
  - “5. Storage racks and shelves shall be in accordance with the provisions of Sec. 80.301(i).
  - “6. Containers shall be approved for the use intended.
  - “7. Individual containers shall not exceed 100 pounds or five-gallon capacity.
  - “8. Incompatible materials shall be separated in accordance with the provisions of Sec. 80.301(n).
  - “9. Floors shall be in accordance with the provisions of Sec. 80.301(z).
  - “10. Aisles four feet in width shall be maintained on three sides of the display area.
  - “11. Hazard identification signs shall be provided in accordance with the provisions of Sec. 80.104(e).”
39. Add Table No. 80.109 to read:

“TABLE 80.109

## DENSITY FACTORS FOR EXEMPT AMOUNTS IN RETAIL SALES

HAZARD CATEGORIES 1	CLASS	DENSITY FACTOR p
PHYSICAL HAZARDS: Oxidizers; unstable (reactive) materials; water-reactive materials	Class 4 Class 3 Class 2 Class 1	N.P. 0.075 0.006 0.003
HEALTH HAZARDS: Toxic or highly toxic solids and liquids; corrosives; other health hazard solids, liquids and gases.	All	0.0013

NP = Not permitted

1-Hazard categories are as specified in Division II. Density factors shall not apply to categories other than those listed.”

40. Sec. 80.306(a)(1). Add an exception to read: “For retail display of nonflammable solid and nonflammable or noncombustible liquid Class 1, Class 2 and Class 3 oxidizers, see Sec. 80.109.”
41. Table No. 80.306-A. Revise the footnotes to read:
- “1) No exempt amounts of Class 4 oxidizers are permitted in Group R Occupancies, offices or retail sales portions of Group B Occupancies.
  - “2) No exempt amounts of Class 4 oxidizers are permitted in Group A, E, I or M Occupancies, or in classrooms of Group B Occupancies unless storage is within a hazardous material storage cabinet containing no other storage.
  - “3) A maximum quantity of 200 pounds of solid or 20 gallons of liquid Class 3 oxidizers may be permitted in Groups I, M and R occupancies when such materials are necessary for maintenance purposes or operation of equipment. The oxidizers shall be stored in approved containers and in a manner approved by the chief.”
42. Sec. 80.309(a). Revise the exceptions to read:
- “1. Detonatable, unstable (reactive) materials shall be stored in accordance with Article 77.
  - “2. For retail display of nonflammable solid and nonflammable or noncombustible liquid unstable (reactive) materials, see Sec. 80.109.”
43. Sec. 80.310(a). Add an exception to read: “For retail display of nonflammable solid and nonflammable or noncombustible liquid water-reactive materials, see Sec. 80.109.”
44. Sec. 80.312(a)(1). Add an exception to read: “For retail display of nonflammable solid and nonflammable or non-

combustible liquid toxic or highly toxic materials, see Sec. 80.109.”

45. Sec. 80.314(a)(1). Add an exception to read: “For retail display of nonflammable solid and nonflammable or non-combustible liquid corrosive materials, see Sec. 80.109.”
46. Sec. 80.315(a)(1). Add an exception to read: “For retail display of nonflammable solid and noncombustible or nonflammable liquid other than health hazard materials, see Sec. 80.109.”
47. Sec. 80.401(b)(3F)(v). Add an exception to read: “Automatic shutdown need not be provided for reactors utilized for the production of toxic or highly toxic gases when such reactors are:
  - “1. Operated at pressures less than 15 psig.
  - “2. Constantly attended.
  - “3. Provided with readily accessible emergency shutoff valves.”
48. Sec. 80.402(c)(8C). Add an exception to read: “Automatic shutdown need not be provided for reactors utilized for the production of toxic or highly toxic gases when such reactors are:
  - “1. Operated at pressures less than 15 psig.
  - “2. Constantly attended.
  - “3. Provided with readily accessible emergency shutoff valves.”
49. Appendix VI-D is modified to include the following after Table 42-B: “Carpeting on walls or ceilings. When used as interior wall or ceiling finish, carpeting and similar materials having napped, tufted, looped or similar surface shall meet the criteria set forth in Enclosed Corner Burn Test, Underwriters Laboratory Subject Outline 1715 (1989 Ed.), which is incorporated by reference herein and on file with the Office of the Secretary of State. Incorporated materials do not include any later amendments or editions of the incorporated matter. This document is available from Underwriters Laboratory, Inc., Publication Department, 1655 Scott Boulevard, Santa Clara, CA 95050.”

#### Historical Note

Adopted as an emergency effective March 24, 1982, pursuant to A.R.S. § 41-1003, valid for only 90 days (Supp. 82-2). Former Section R8-2-41 adopted as an emergency now adopted as a permanent rule effective June 24, 1982 (Supp. 82-3). Adopted as an emergency effective October 12, 1984, pursuant to A.R.S. § 41-1003, valid for only 90 days (Supp. 84-5). Emergency expired. former Section R8-2-41 repealed, new Section R8-2-41 adopted effective April 2, 1985 (Supp. 85-2). Former Section R8-2-41 repealed, new Section R4-34-1101 adopted as an emergency effective March 14, 1988, pursuant to A.R.S. § 41-1026, valid for only 90 days (Supp. 88-1). Emergency expired. Former Section R8-2-41 repealed, new Section R4-34-1101 adopted as a permanent rule with editorial corrections effective November 16, 1988 (Supp. 88-4). Section R4-34-1101 repealed, new Section adopted effective July 20, 1990 (Supp. 90-3). Section R4-36-201 renumbered from R4-34-1101 (Supp. 95-4).

**Editor’s Note:** Article 3, consisting of Sections R4-26-301 through R4-36-308, repealed by summary action with an interim effective date of December 26, 1997. Historical notes in this Article were corrected for clarification in Supp. 98-2. Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

### ARTICLE 3. REPEALED

#### R4-36-301. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-301 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-302. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-302 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-303. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-303 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-304. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-304 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-305. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-305 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-306. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-306 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4). Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

#### R4-36-307. Repealed

##### Historical Note

Adopted effective November 1, 1995 (Supp. 95-4). R4-36-307 repealed by summary action with an interim effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4).

Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).

**R4-36-308. Repealed**

**Historical Note**

Adopted effective November 1, 1995 (Supp. 95-4).  
R4-36-308 repealed by summary action with an interim

effective date of December 26, 1997; filed in the Office of the Secretary of State December 5, 1997 (Supp. 97-4).  
Adopted summary rules filed June 5, 1998; interim effective date of December 26, 1997, now the permanent effective date (Supp. 98-2).